

Properties	Unit	Specification	Test Method
Color		2 max	ASTM D 1500
Cloud Point	°C	Report	ASTM D 2500 or 5773
Cold Filter Plug Point	°C	Report	ASTM D 6371/ IP 909
Cetane Index		50	ASTM D 4737
Cetane Number		55	ASTM D 613
Carbon Residue	%Wt	0.2	ASTM D 4530
Particular Contaminates	mg/L	20 max	ASTM D 6217
Ash Content	%Wt	0.01 max	ASTM D 482
Appearance		Clear	Visual
Acidity		0.1 nil	ASTM D 974
Copper Corrosion		1 max	ASTM D 130
Density @15°C	kg/L	0.82-0.845	ASTM D 1298 or 4052
Distillation @90% recovery	°C	357	ASTM D 88
Filter Plugging Tendency		1.4	ASTM D 2088
Flash Point PMCC	°C	54-62	ASTM D 93
Pour Point	°C	0	ASTM D 5948
Total Aromatics	%Wt	10	ASTM D 5186
Sulfur Content	%Wt	0.5-0.7	ASTM D 4294

